

SUBJECT: Indexing of Panel Boards

EFFECTIVE DATE: October 25, 2010

INTERPRETATION NUMBER: ADM – 4.0408.30 (formerly 4.0384.13)

SEE ALSO: 2005 NEC – Article 408.30

INTERPRETATION SUMMARY

This article requires that all circuits in panel boards are to be identified on the face or inside of the door of the panel board. It is the interpretation of this department that this requirement applies to all circuits in new panel boards, not only those new circuits that are being added to a new panel board. Whenever a new panel board is installed all circuits must be identified.