



## Sewer Inspection Checklist

**DRAFT**

<b>Address:</b>	<b>Contractor:</b>	<b>Permit #</b>
-----------------	--------------------	-----------------

*The following checklist is not all-inclusive. Other code related requirements may be included in this inspection*

OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 103.1.2 Verify that work conforms with plans	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC Table 7-7 Check clearance to potable water lines.
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 719.0 Verify proper use and location of cleanouts. (Cleanouts required every 100' and every 135° of direction change.)	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	City Memo dated July 3, 2002 Verify that all connections made in the easement or right-of-way with a rubber coupling are with a shielded coupling.
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 717.0, 718.1 Verify sewer size and grade with respect to fixture load.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 721.0 Check location of sewer with regard to property lines and easements.
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 718.2 Verify that all horizontal pipe is bedded on undisturbed soil, compacted soil or granular fill.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 718.3 Verify minimum cover (12")
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 316.2.3 Verify connection between dissimilar materials is made by means of approved mechanical fitting.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	City Memo dated July 3, 2002 Verify proper connection to public sewer main.
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>		OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	

Notes:

Date		Inspector	
------	--	-----------	--