



Storm Drainage Systems In or On a Commercial Building Inspection - Checklist
DRAFT

Address:	Contractor:	Permit #
-----------------	--------------------	-----------------

The following checklist is not all-inclusive. Other code related requirements may be included in this inspection

OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 103.1.2 Verify that work conforms with plans. Check method of secondary drainage.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 1101.11.2.2, 1101.2 Verify that primary and secondary drains run to approved locations.
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 1101.11.2.3 Verify that secondary drains and scuppers are at correct height.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 1109.2 Verify system air or water test (per local amendment, tests are not required for PVC and ABS systems)
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 1106.0, Tables 11-1, 11-2, 11-3 Verify leader, conductor, scupper, and gutter size. Check that horizontal offsets are correct slope.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 1101.12 Verify that appropriate cleanouts have been installed.
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 1102.1.2, 1102.2.2 Ensure proper materials for leaders and conductors are used.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 1104.2 Verify that leaders in hazardous locations are protected.
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC 1105.2, 1105.3 Ensure that domes and strainers are of the proper size and height.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	UPC Table 3-2 Verify that storm drainage piping is properly supported.
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>		OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	

Notes:

Date	Inspector	
------	-----------	--