



## Rough Framing Inspection Checklist - Conventional Wood Rafters

**DRAFT**

<b>Address:</b>	<b>Contractor:</b>	<b>Permit #</b>
-----------------	--------------------	-----------------

**The following checklist is not all-inclusive. Other code related requirements may be included in this inspection.**

OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Check that the description of the work conforms to the approved plans, specifications and special conditions.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Table 503.2.1.1 (1)—Check maximum spans for roof sheathing material.
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	R301—VERIFY THAT ALL LOADS ARE TRANSFERRED TO THE FOUNDATION.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Table 802.5.5 (1)—Check rafter spans.
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Table 802.4 (1). Check size, spacing, loading and span of ceiling joists.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	R802.9—Verify method of framing openings in ceiling and /or roof.
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	R802.3—Verify that ridge, hips and valleys are at least the depth of the cut end of the rafters.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	R802.7.1—Check that notch (bird mouth) at end of rafter, measured at the inside of the wall and does not exceed ¼ depth of rafter.
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	R802.3—Check to see that hips and valleys are supported to a bearing partition or by other means.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	R807 and R806—Check that attic access and ventilation are being provided.
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	R802.3.1—Verify method of providing rafter ties at the plate line.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	R301—Check size of all beams, including structural ridges.
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Table 802.5.1. (1)-footnote a—determine rafter span if rafter tie is not located at the plate line.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	

Notes:

Date		Inspector	
------	--	-----------	--