



Kansas Health & Environmental Laboratories
1115 SW Harrison Street
Topeka, KS 66612
Phone (785) 296-1620
Fax (785) 559-5205

Analytical Results

FINAL

Submitter: KDHE North Central District Office
Report To: Jennifer Nichols
KDHE North Central District Office
3040 Enterprise Dr.
Salina, KS 67401

Client ID: 5DT00
State ID:
Collector: MARSHA FLEMING
Collection ID/Chain#: KIT1217406

Lab ID: 3261787
Sample ID: Env Micro SP
Description: DS1
Matrix: Drinking Water
SDWIS Sample Type: SP

Date Collected: 08/10/2026 13:13
Date Received: 08/11/2026 11:49
Location Description: 1
Location Code: SP01
Workorder ID: 2723370

Parameter	Results	Units	RDL	DF	Unc.	Prepared	By	Analyzed	By	Qual	RegLmt
(Microbiology/SM 9223-B)											
Total Coliform via P/A	Absent			1		08/11/2026 14:36	GEM	08/12/2026 08:38	GEM		
E. coli via P/A	Absent			1		08/11/2026 14:36	GEM	08/12/2026 08:38	GEM		
(N/A)											
Total Chlorine Residual	1.75			1		08/11/2026 12:14	MSJ	08/11/2026 12:14	MSJ		